

# TEST CERTIFICATE


CT-24-05-28-02

- Product:** Lightweight panel lisocore®  
Standard assortment wood fibre cover layers  
Thickness range: 15 – 60 mm  
Thickness: 15 mm | 60 mm
- Manufacturer:** Pyrus Panels GmbH  
Carl-von-Ossietzky-Str. 17 - 21  
83043 Bad Aibling  
Germany
- Order:** Determination of the formaldehyde release according to the test chamber method DIN EN 16516
- Test method:** Test chamber method and analytic according to DIN EN 16516 (10/2020)
- Report:** Test report 2524073/1 and test report 2524073/2 dated 14 May 2024
- Test result:** The formaldehyde release of the tested 15 mm product is  $94 \mu\text{g}/\text{m}^3$  and of the tested 60 mm product is  $78 \mu\text{g}/\text{m}^3$ .  
The above-mentioned lightweight panels lisocore® Standard assortment wood fibre cover layers meet the material guideline value of  $124 \mu\text{g}/\text{m}^3$  regarding the formaldehyde emission and fulfils the requirements according to German Chemical Prohibition Ordinance appendix 1 of §3 dated 2017-01-20 in connection with BAnz AT 26.11.2018 B2.

Dresden, 28 May 2024



Head of laboratory



Engineer in charge